

CERTIFICATE OF WATER TANKER SHUTTLE ACCREDITATION

Presented to

Stone Mills Fire Department

F.S. #1 Yarker (7)
F.S. #2 Enterprise (7)
F.S. #3 Newburgh (7)
F.S. #4 Tamworth (7)

Date Test Passed: September 18th, 2020

Flow Achieved: 626 I.G.P.M Liters Per Min: 3000
Two (2) Hour Test Time

Signed: *Melissa Rose*
Melissa Rose – Principal

This Certificate is valid for 5 years and expires September 18th, 2025