Township of Stone Mills – Entrance Permit № 20 -



Public Works

1998	
Property Owner:	
Phone & Email: Location of Entrance:	
Property Roll:	
Legal Description:	
Admin Fee:	[□] \$ 100.00 Civic # Replacement [□] \$ 20.00
Civic # Addressing Fee:	□ \$ 150.00 Civic # Replacement Installed □ \$ 100.00
Refundable Performance Bond:	
Date:	
	lars specific to this application: Date:
	Commercial Farm Field
	_ Culvert Dimensions:
	m (6") of Granular "A" material on a firm base constructed to a
minimum 4.9m (16'), maximum 9.1m (30') width.	
General Entrance Installation Requirements	
Minimum length of new entrance culvert to be 9.0m unless otherwise noted. Minimum and maximum widths of entranceway between surface edges measured perpendicular to the	
centreline of the entranceway to be 4.9m and 9.1m respectively.	
Minimum depth of granular material and cover over entranceway culvert to be 150mm (6").	
Bottom of culvert to be set 75mm below ditch elevation.	
Entrance culvert shall consist of new CSA approved Corrugated Plastic pipe.	
Asphalt pavement for residential entrances to be placed at 50mm depth after compaction.	
Asphalt pavement for commercial entranceways to be placed from pavement edge to property line or end of fillet, whichever is closer to roadway pavement.	
Entranceway fill materials should be placed on a maximum 3:1 slope. Concrete pavements, concrete	
structures, pillars or headwalls of any type shall not be allowed on the Township road allowance.	
Centreline of entranceway to meet the projected centreline of the roadway at an angle of 90°.	
Entranceways to be constructed by applicants at their cost.	
Addition Requirements:	
Please contact this office for approval review and deposit release.	
Date Reported for Final Inspection:	
The provisions have been met and the performance bond can be refunded to:	
Pick Up: D	

300-4421 Revenue / 300-5261 Return

Date of Final Inspection:

_____ Road Authority: _